

No.804/2019

Fire & Rescue Station,  
Thiruvananthapuram,  
Date: 11.07.2019

Station Officer,  
Fire & Rescue Station,  
Thiruvananthapuram,

Principal,  
NSS Public School,  
Perunthanni.  
Thiruvananthapuram.

Sir,

Subject:- Fire & Rescue Station, Thiruvananthapuram – Certificate of Approval – Return of Application and annexure documents submitted - regarding

Reference:-1)Lr. No.F2-9400/16 dated 16.04.2019 of the Director of Fire & Rescue.  
2)G.O.(P)No.81/17 LSGD dated 31.10.17  
3)G.O.(P)No.82/17 LSGD dated 31.10.17  
4)Your Letter dated 11.07.2019.

As per the amendments made in Kerala Panchayat Building Construction Rules and Kerala Municipality Building Construction Rules, Educational Buildings having height above 15 meters or buildings having area above 1000 Sq. Mts. are only required to obtain no objection certificate from this department. The applicants can take further steps based on a Self Certification in respect to the Buildings less than the above measurements. As per the documents submitted height of the buildings is less than 15 meters and area is less than 1000 Sq. Mtrs. As such Your application and annexure documents are returned herewith.

Yours faithfully,

Sd/-

Station Officer,  
Fire and Rescue Station  
Thiruvananthapuram.

(Seal)

*Mina A*

PRINCIPAL  
N.S.S. PUBLIC SCHOOL  
PERUNTHANNI THIRUVANANTHAPURAM

Attested

*[Signature]*

This letter is translated from Malayalam to English.



*[Signature]*  
GENERAL MANAGER & INSPECTOR  
N.S.S. SCHOOLS



KAIKASI V. S.  
Asst. Professor  
Dept. of English  
University College  
Thiruvananthapuram